



TERMS AND CONDITIONS FOR ULTRATECH MAXSHEEN

- Subgrade preparation – the subgrade should be well compacted and to have a k value of 0.08 N/mm³ or Proctor density 98%.
- Minimum grade M25 and minimum thickness of 75mm.
- The surface regulation of floor should be preferably FM2.